

## CHAPTER 4 SPECIAL DETAILED REQUIREMENTS BASED ON USE AND OCCUPANCY

*Amend Chapter 4 by creating new, deleting or adding to various sections, as follows:*

**405.1 General.** *Amend to add:* Exceptions: 6. Developed subterranean spaces in compliance with Section 422 of this code and NFPA 520.

**407.1 General.** *Amend to read:* “All occupancies in Group I-2 shall comply with the provisions of NFPA 101. In addition, the following sections of this code shall apply: Table 503 (Area Limitations Only), Sections 106.1.1.1, 410, 412.5, 506, 507, Chapter 6, 704, 705, 707.11, 707.12, 710, 711, 714, 716, 717, 804.4, 805, 104.3.2.4, 1006.2.2, 1003.3.3.12, Chapter 11, 1208.2, Chapter 13, Chapter 14, 2406.2, and Chapters 16 through 34.”

**407.2 Deleted.**

**407.2.1 Deleted.**

**407.2.2 Deleted.**

**407.2.3 Deleted.**

**407.2.4 Deleted.**

**407.3 Deleted.**

**407.3.1 Deleted.**

**407.3.2 Deleted.**

**407.4 Deleted.**

**407.4.1 Deleted.**

**407.4.2 Deleted.**

**407.5 Deleted.**

**407.6 Deleted.**

**408.1 General.** *Amend section and create subsections to read:* “Occupancies in Group I-3 shall comply with the provisions of this section and other applicable provisions of this code (see Section 308.4).”

**408.1.1 “State Jail” Definition.** “Any Use Group I-3 facility under the direct supervision and operation of the Commonwealth of Kentucky. State jails shall comply with Sections 408.2 through 408.8 of this code.

**408.1.1.1 “Local Jail” Definition.** Any Use Group I-3 facility under the supervision of a county, regional jail authority, city or urban county government. Local jails shall comply with the special requirements of Section 408.9, Local jails, in addition to the requirements of Sections 408.2 through 408.8 of this code.

For the purpose of applying the special requirements of Section 408.9 for local jails the following definitions shall be applicable:

***Amend Exception 1. as follows: (Amendment underlined)***

**Exceptions:**

1. Buildings and structures of Types I and II construction for rack storage facilities, which do not have access by the public shall not be limited in height provided that such buildings conform to the requirements of Section 507.1 NFPA 13 and NFPA 230.
2. The automatic sprinkler system shall not be required over the spectator seating area or in areas occupied for indoor participant sports, such as tennis, skating, swimming and equestrian activities, in occupancies in Group A-4, provided that:
  - 2.1 Exit doors directly to the outside are provided for occupants of the participant sports areas;
  - 2.2 The building is equipped with a fire alarm system with manual fire alarm boxes installed in accordance with Section 907; and
  - 2.3 All other areas of the building shall be protected with an automatic sprinkler system.
3. Unlimited area Group M buildings may have tenant spaces of Group A-2 and Group A-3 assembly occupancies, provided the area of the tenant space does not exceed the allowable area permitted by Section 503. The assembly occupancy tenant space shall be separated from adjacent tenants by I-hour tenant separation walls. The aggregate area of assembly occupancies located within the building shall not exceed 10 percent of the total building area.
4. Buildings of assembly occupancy Group A-3 used exclusively as auditoriums, exhibition halls, health clubs, fitness clubs, gymnastic clubs, passenger station waiting areas or gymnasiums, indoor swimming pools, and indoor tennis courts without spectator seating, shall not be limited in area in accordance with this section.

**507.2 Two-story.** The area of a two-story, Group B, F, M or S building shall not be limited when the building is provided with an automatic sprinkler system throughout in accordance with Section 903.3.1.1, and is surrounded by public ways or yards not less than 60 feet (18288 mm) in width.

**507.2.1 Two-story Group A-3 occupancies.** The area of a two-story assembly occupancy of Group A-3 occupied exclusively as auditoriums, exhibition halls, health or fitness clubs, gymnastic clubs, passenger station waiting areas or gymnasiums, indoor swimming pools, and indoor tennis courts without spectator seating shall not be limited, provided that:

1. The building shall be provided with an automatic sprinkler system throughout in accordance with Section 903.3.1.1.
2. The building is equipped with a fire alarm system with manual fire alarm boxes installed in accordance with Section 907.
3. The building is surrounded by public ways or yards not less than 60 feet (18288 mm) in width.

**508.9 Day care centers within buildings having other use groups or constructed as separate buildings.** *Create a new subsection to read:* “Day care centers shall be limited to the height and area limits of Table 503 for the occupancy group and construction type and shall be further limited as to location and permissible construction type in accordance with Table 420.2 of this code.”

with tenant, guestroom and dwelling unit separation walls that do not extend to the underside of the roof sheathing above.”

“5. When tenant, guestroom and dwelling unit separation walls are constructed to the underside of a fire-resistance-rated floor/ceiling assembly or to a ceiling with a 60-minute finish rating, the attic draftstopping complying with Section 716.4.3 shall be deemed equivalent.”

**719.1 General.** *Delete in its entirety.*

**720.1 General.** *Delete in its entirety.*

## **CHAPTER 8**

### **INTERIOR FINISHES**

No changes

## **CHAPTER 9**

### **FIRE PROTECTION SYSTEMS**

*Amend Chapter 9 by creating new, deleting or adding to various sections, as follows:*

**901.6.2 Fire alarm systems.** *Create two new Exceptions to read:*

- “3. Day care centers with 100 or less clients.
4. Churches or other similar religious facilities.”

**901.6.3 Group H.** *Delete the Exception to this subsection in its entirety.*

**902.1** *Amend by deleting the definition of “Constantly Attended Location”.*

**903.2.1.1 Group A-1.** An automatic sprinkler system shall be provided throughout a fire area containing a Group A-1 occupancy where one of the following conditions exists:

1. The fire area exceeds 12,000 square feet (1115 m<sup>2</sup>).
2. The fire area is located on a floor other than the level of exit discharge.

**903.2.1.3 Group A-3.** *Amend to read:* “An automatic sprinkler system shall be provided throughout a fire area containing a Group A-3 occupancy where one of the following conditions exists:

1. The fire area exceeds 12,000 square feet.
2. The fire area is located on a floor other than the level of exit discharge.”

Exception: Churches and similar religious facilities.

## CHAPTER 11 ACCESSIBILITY

*Amend Chapter 11 by creating new, deleting or adding to various sections, as follows:*

**1101.2 Design.** *Amend subsection to read: “Buildings and facilities shall be designed and constructed to be accessible in accordance with this code and applicable accessibility standards published or proposed by the Department of Justice (DOJ) and adopted by the Housing, Buildings and Construction Board. These DOJ standards shall hereafter be referred to as “ADAAG” (American with Disabilities Act Accessibility Guidelines).”*

**1102.1 Definitions.** *Amend or create additional definitions as follows:*

**“ACCESSIBLE ROUTE:** A continuous, unobstructed path connecting all accessible elements and spaces of a building or facility. Interior accessible routes may include corridors, floors, ramps, elevators, lifts and clear floor space at fixtures. Exterior accessible routes include parking access aisles, curb ramps, walks ramps and lifts.”

**ACCESSIBLE UNIT. A dwelling unit or sleeping unit that complies with this code and ADAAG.**

**“ADAAG:** The Americans with Disabilities Act Accessibility Guidelines for buildings and facilities developed by the U. S. Architectural and Transportation Barriers Compliance Board for use in new construction involving public accommodations, commercial facilities and state and local government buildings.

**“CHILDREN’S USE.** Spaces or elements specifically designed for use primarily by people between the ages of 5 years and 12 years of age.”

**DELETE: DWELLING UNIT, GROUND FLOOR.**

**DWELLING UNIT OR SLEEPING UNIT, MULTISTORY.** A dwelling unit or sleeping unit with habitable space located on more than one story.

**“DWELLING UNIT OR SLEEPING UNIT, TYPE A.** A dwelling unit ~~or sleeping unit~~ designed and constructed for accessibility in accordance with ADAAG.”

**“DWELLING UNIT OR SLEEPING UNIT, TYPE B.** A dwelling unit ~~or sleeping unit~~ designed and constructed for accessibility in accordance with ADAAG, consistent with the design and construction requirements of the federal Fair Housing Act and pursuant to KRS 344.360 (11)-(13).”

**INTENDED TO BE OCCUPIED AS A RESIDENCE.** *This refers to a dwelling unit or sleeping unit that can or will be used all or part of the time as the occupant's place of abode.*

**1103.2.11 Residential Group R-1.** Buildings of Group R-1 containing not more than five sleeping units for rent or hire that are also occupied as the residence of the proprietor are not required to be accessible.

**1103.2.13 Church buildings.** *Create a new subsection to read: “Buildings or portions thereof used as a church are not required to be accessible.”*

**1103.2.14 Child day care facilities.** *Create a new subsection to read:* “Buildings or portions thereof used as a child day care facility are not required to comply with the provisions found in ADAAG for children. Those areas of child day care facilities used by staff or parents of the children shall be made accessible. This would include, **but not be limited to**, accessible parking, accessible route to the building/facility entrance, accessible route within the facility to all occupiable rooms and spaces. “

**1104.4 Multilevel buildings and facilities.** *Amend Exception 1 and delete Exception 2 as follows:*  
**Exceptions:** 1. The exceptions found in Section 206.2.3 of ADAAG.

**1104.6 Accessible routes.** *Create a new subsection to read:* “Accessible routes shall be provided in accordance with this section and Section 206 of ADAAG.”

**1104.7 Public toilet facilities.** An accessible route shall be provided to all public toilet facilities when provided or otherwise required by the Kentucky Plumbing Code. The accessible route shall be accessible to the general public and shall not be located in areas of the building that are restricted or noted as restricted to "Employees Only".

**1106.1 Required.** *Amend this subsection by adding the following language to the end:* “and shall comply with Section 208 of ADAAG.”

**1106.2 Groups R-2 and R-3.** *Amend this subsection to read:* “Parking spaces provided to serve residential facilities shall comply with 208.2.3 of ADAAG.”

**1106.3 Rehabilitation facilities, outpatient physical therapy and hospital outpatient facilities.** *Amend the title of the subsection to include “hospitals and outpatient facilities”.*

**1106.6 Passenger loading zones.** *Amend this subsection to read:* “Passenger loading zones shall be designed and constructed in accordance with 209 of ADAAG.”

**1107.2 Assembly area seating.** *Amend subsection to read:* “Assembly areas with fixed seating shall comply with Sections 1107.2.1 through 1107.2.4.1 and the provisions of Section 221 of ADAAG. Dining areas shall comply with Sections 1107.2.5 through 1107.2.5.2 and the provisions of Section 226 of ADAAG.”

**Amend Table 1107.2.2.1. Amend the Table as follows: TABLE 1107.2.2.1**

**WHEELCHAIR SPACE CLUSTERS**

NUMBER OF SEATS <sup>a</sup>	MINIMUM NUMBER OF WHEELCHAIR SPACES REQUIRED
Up to 300	1
301 to 600	2
601 to 900	3
901 to 1, 500	4
1,501 to 2,100	5
2,101 to 3,000	6
OVER 3,000	6, plus 1 additional space for each total seating capacity increase of 100, or fraction thereof, over 500

a. Installed seats plus required wheelchair spaces.

**1107.2.3.1 Multilevel assembly seating areas.** *Amend subsection to read:* “In multilevel assembly seating areas, wheelchair space clusters shall be provided on the main floor level and on one of each two additional floor or mezzanine levels when an accessible route is provided.”

**1107.2.4 Assistive listening systems.** *Amend subsection and create Exception to read:* “Stadiums, theaters, auditoriums, lecture halls and similar fixed seating assembly areas where audible communications are integral to the use of the space shall have an assistive listening system, complying with this section and 219 of ADAAG, if the area is equipped with an audio amplification system.

**Exception:** Courtrooms shall have an assistive listening system even if an audio amplification system is not provided.”

**1107.3.3 Group I-3.** *Amend subsection to read:* “Occupancies in Group- I-3 shall comply with 233 of ADAAG.”

**1107.3.4 Alterations.** *Create new subsection to read:* “Alterations to facilities in Group I-1 and I-2 shall comply with 223.1.1 of ADAAG.”

**1107.4 Care facilities.** *Delete subsection, including Exception, in its entirety.*

**1107.5 Group R..** In addition to the other requirements of this chapter, occupancies having dwelling units or sleeping units shall be provided with accessible features in accordance with Sections 1107.5.1 through 1107.5.7.

**DELETE CURRENT SECTION 1107.5.1, and replace with:**

**1107.5.1 Design.** Type A and Type B dwelling units and sleeping units, which are required to be accessible units, shall comply with this code and Chapter 11 of ADAAG. Units required to be Type B units are permitted to be designed and constructed as Type A units.

**Table 1107.5.1, Accessible Sleeping Accommodations,** *delete Table in its entirety.*

**1107.5.2 Accessible spaces.** Rooms and spaces available to the general public or for the use of the residents and serving accessible units, Type A units or Type B units, shall be accessible. Accessible spaces shall include toilet and bathing rooms, kitchen, living and dining areas, and any exterior spaces, including patios, terraces and balconies.

**Exception:** Recreational facilities in accordance with Section 1108.14.

**DELETE CURRENT SECTION 1107.5.3, and replace with:**

**1107.5.3 Accessible route.** At least one accessible route shall connect accessible building or facility entrances with the primary entrance of each accessible unit, Type A and Type B units, within the building or facility and with those exterior and interior spaces and facilities that service the units.

**Exception:**

1. If the slope of the finished ground level between accessible facilities and buildings exceeds one unit vertical in 12 units horizontal (8 percent slope), or where physical barriers prevent the installation of an accessible route, a vehicular route with parking that complies with Section 1106 at each public or common use facility or building is permitted in place of the accessible route.

2. NO CHANGE

**DELETE CURRENT SECTION 1107.5.4, and replace with the following:**

**1107.5.4 Group R-1.** In occupancies of Group R-1, accessible dwelling units and sleeping units shall comply with Section 224 of ADAAG. The number of accessible sleeping accommodations shall comply with Table 224.2 of ADAAG. All facilities on a site shall be considered to determine the total number of accessible units. Accessible units shall be dispersed among the various classes of units. Roll-in showers provided in accessible units shall include a permanently mounted folding shower seat.

**1107.5.4.1 Type B units.** In structures with four or more dwelling units or sleeping units intended to be occupied as a residence, every dwelling and sleeping unit to be occupied as a residence shall be a Type B unit.

**Exception:** The number of Type B units is permitted to be reduced in accordance with Section 1107.5.8.

**DELETE CURRENT SECTION 1107.5.5, and replace with the following:**

**1107.5.5 Group R-2.** Type A and Type B units shall be provided in occupancies in Group R-2 in accordance with Sections 1107.5.5.1 and 1107.5.5.2.

**1107.5.5.1 Type A units.** In occupancies in Group R-2 containing more than 20 dwelling units or sleeping units, at least 2 percent, but not less than one, of the units shall be a Type A unit. All units on a site shall be considered to determine the total number of units and the required number of Type A units. Type A units shall be dispersed among the various classes of units.

**Exceptions:**

1. The number of Type A units is permitted to be reduced in accordance with Section 1107.5.8.
2. Existing structures on a site shall not contribute to the total number of units on a site.

**1107.5.5.2 Type B units.** Where there are four or more dwelling units or sleeping units intended to be occupied as a residence in a single structure, every dwelling unit and sleeping unit intended to be occupied as a residence shall be a Type B unit.

**Exceptions:** The number of Type B units is permitted to be reduced in accordance with Section 1107.5.8.

**DELETE CURRENT SECTION 1107.5.6, and replace with the following:**

**1107.5.6 Group R-3.** In occupancies in Group R-3 where there are four or more dwelling units or sleeping units intended to be occupied as a residence in a single structure, every dwelling and sleeping unit intended to be occupied as a residence shall be a Type B unit.

**Exception:** The number of Type B units is permitted to be reduced in accordance with Section 1107.5.8.

**DELETE CURRENT SECTION 1107.5.7, and replace with the following:**

**1107.5.7 Group R-4.** Group R-4 occupancies shall be provided with accessible features in accordance with Sections 1107.5.7.1 and 1107.5.7.2.



**1107.5.7.1 Accessible units.** At least one of the dwelling or sleeping units shall be an accessible unit.

**1107.5.7.2 Type B units.** In structures with four or more dwelling or sleeping units intended to be occupied as a residence, every dwelling and sleeping unit intended to be occupied as a residence shall be a Type B unit.

**Exceptions:** The number of Type B units is permitted to be reduced in accordance with Section 1107.5.8.

**DELETE CURRENT SECTION 1107.5.8, and replace with the following:**

**1107.5.8 General Exceptions:** Where specifically permitted by Sections 1107.5, the required number of Type A and Type B units is permitted to be reduced in accordance with Sections 1107.5.8.1 through 1107.5.8.5.

**1107.5.8.1 Buildings without elevator service.** Where no elevator service is provided in a building, only the dwelling and sleeping units that are located on stories indicated in Sections 1107.5.8.1.1 and 1107.5.8.1.2 are required to be Type A and Type B units. The number of Type A units shall be determined in accordance with Section 1107.5.5.

**1107.5.8.1.1 One story with Type B units required.** At least one story containing dwelling units or sleeping units intended to be occupied as a residence shall be provided with an accessible entrance from the exterior of the building and all units intended to be occupied as a residence on that story shall be Type B units.

**1107.5.8.1.2 Additional stories with Type B units.** On all other stories that have a building entrance in proximity to arrival points intended to serve units on that story, as indicated in Items 1 and 2, all dwelling units and sleeping units intended to be occupied as a residence served by that entrance on that story shall be Type B units.

1. Where the slopes of the undisturbed site measured between the planned entrance and all vehicular or pedestrian arrival points within 50 feet of the planned entrance are 10 percent or less, and
2. Where the slopes of the planned finished grade measured between the entrance and all vehicular or pedestrian arrival points within 50 feet of the planned entrance are 10 percent or less.

Where no such arrival points are within 50 feet of the entrance, the closest arrival point shall be used unless that arrival point serves the story required by Section 1107.5.8.1.1.

**1107.5.8.2 Multistory units.** A multistory dwelling or sleeping unit which is not provided with elevator service is not required to be a Type B unit. Where a multistory unit is provided with external elevator service to only one floor, the floor provided with elevator service shall be the primary entry to the unit, shall comply with the requirements for Type B unit, and a toilet facility shall be provided on that floor.

**1107.5.8.3 Elevator service to the lowest story with units.** Where elevator service in the building provides an accessible route only to the lowest story containing dwelling or sleeping units intended to be occupied as a residence, only the units on that story which are intended to be occupied as a residence are required to be Type B units.



**1107.5.8.4 Site impracticability.** On a site with multiple non-elevator buildings, the number of units required by Section 1107.5.8.1 to be Type B units is permitted to be reduced to a percentage which is equal to the percentage of the entire site having grades, prior to development, which are less than 10 percent, provided that all of the following conditions are met:

1. Not less than 20 percent of the units required by Section 1107.5.8.1 on the site are Type B units,
2. Units required by Section 1107.5.8.1, where the slope between the building entrance serving the units on that story and a pedestrian or vehicular arrival point is no greater than 8.33 percent, are Type B units,
3. Units required by Section 1107.5.8.1, where an elevated walkway is planned between a building entrance serving the units on that story and a pedestrian or vehicular arrival point and the slope between them is 10 percent or less are Type B units, and
4. Units served by an elevator in accordance with Section 1107.5.8.3 are Type B units.

**1107.5.8.5 Base flood elevation.** The required number of Type A and Type B units shall not apply to a site where the lowest floor or the lowest structural building members of non-elevator buildings are required to be at or above the base flood elevation resulting in:

1. A difference in elevation between the minimum required floor elevation at the primary entrances and vehicular and pedestrian arrival points within 50 feet exceeding 30 inches, and
2. A slope exceeding 10 percent between the minimum required floor elevation at the primary entrance and vehicular and pedestrian arrival points within 50 feet.

Where no such arrival points are within 50 feet of the primary entrances, the closest arrival point shall be used.

**1107.6 Self-service storage facilities.** *Amend subsection to read:* “Self-service storage facilities shall provide accessible individual self-storage spaces in accordance with Table 1107.6 and shall comply with Section 225 of ADAAG.”

**1108.1 General.** *Amend subsection and Exception to read:* “Accessible building features and facilities shall be provided in accordance with Sections 1108.2 through 1108.20.”

**“Exception:** Type A and Type B dwelling units shall comply with ADAAG.”

**1108.2 Toilet and bathing facilities.** *Amend subsection and Exceptions as follows:*

- 1. creating additional language to end of first sentence which reads, “and shall comply with this section and Section 213 of ADAAG.”*
- 2. Delete reference to “ICC/ANSI A117.1” in Exceptions and replace with “ADAAG”.*
- 3. In Exception 4, delete the reference to “and primary school”.*

**1108.2.1 Unisex toilet and bathing rooms.** *Amend by deleting Exception in its entirety and amending subsection to read:* “The use of unisex toilet and bathing rooms shall comply with the plumbing code listed in Chapter 35 and this section.”

**1108.2.1.1 Standard.** *Amend subsection to read:* “Unisex toilet and bathing rooms shall comply with this section and 213.2.1 of ADAAG.”

**1108.2.1.2 Unisex toilet rooms.** *Amend Exception to read:*

**“Exception:** A separate-sex toilet room or a room containing only one water closet and one urinal shall be considered a unisex toilet room.”

**1108.2.1.4 Location.** *Amend subsection to read: “Unisex toilet and bathing rooms shall be located on an accessible route.”*

**1108.2.1.5 Prohibited location.** *Delete subsection in its entirety.*

**1108.2.2 Water closet compartment.** *Amend subsection by replacing reference to “ICC/ANI A117.1” with “213.3.1 of ADAAG.”*

**1108.3 Sinks.** *Amend subsection as follows:*

1. *Replace reference to “ICC/ANI A117.1” with “212 of ADAAG.”*
2. *Delete “and primary school” from Exception 2.*

**1108.4 Kitchens, kitchenettes and wet bars.** *Amend subsection by replacing reference to “ICC/ANI A117.1” with “212 of ADAAG.”*

**1108.8 Storage.** *Amend subsection by replacing reference to “ICC/ANI A117.1” with “228 of ADAAG.”*

**1108.12.1 Dressing, fitting and locker rooms.** *Amend subsection by inserting additional language, “and comply with 222 of ADAAG” to end of paragraph.*

**1108.12.2 Check-out aisles.** *Amend subsection by:*

1. *Inserting additional language to the end of the first sentence to read: “and shall comply with Section 227 of ADAAG.”*
2. *Deleting Exception in its entirety.*

**1108.13 Controls, operating mechanisms and hardware.** *Amend subsection by inserting additional language, “and comply with 205 of ADAAG” to end of paragraph.*

**1108.13.1 Operable windows.** *Amend subsection and delete Exception in its entirety: “Where operable windows are provided in rooms that are required to be accessible in accordance with Sections 1107.3.1, 1107.3.2, 1107.5.1 and 1107.5.4, at least one window in each room shall be accessible and each required operable window shall be accessible and comply with Section 230 of ADAAG.”*

**1108.14.1 Groups R-2 and R-3.** *Amend subsection by inserting the language, “or adaptable” following the word “accessible” and before the words “dwelling units”.*

**1108.15 Accessible means of egress.** *Create a new subsection to read: “In new construction, all accessible spaces shall be provided with an accessible means of egress complying with Section 207 of ADAAG.”*

**1108.16 Stairways.** *Create a new subsection to read: “Interior and exterior stairs that are part of a means of egress shall comply with Section 210 of ADAAG.”*

**1108.17 Laundry equipment.** *Create a new subsection to read: “Where washing machines and clothes dryers are provided in spaces required to be accessible, the laundry equipment shall comply with Section 214 of ADAAG.”*

**1108.18 Emergency alarm systems.** *Create a new subsection to read:* “Where fire alarm systems are provided in public and common use areas, the system shall comply with Section 215 of ADAAG.”

**1108.19 Telephones.** *Create a new subsection to read:* “Where telephones are provided, they shall comply with Section 217 of ADAAG.”

**1108.20 Transportation facilities.** *Create a new subsection to read:* “Transportation facilities shall comply with Section 218 of ADAAG.”

**1108.21 Automatic teller machines and fare machines.** *Create a new subsection to read:* “Where automatic teller machines or self-service fare machines are provided, they shall comply with Section 220 of ADAAG.”

**1108.22 Depositories, vending machines, change machines and mail boxes.** *Create a new subsection to read:* “Where provided, these features shall comply with Section 229 of ADAAG.”

**1108.23 Two-way communication systems.** *Create a new subsection to read:* “Where a two-way communication system is provided to gain admittance to a building or facility or to restricted areas within a building or facility, the system shall comply with Section 231 of ADAAG.”

**1108.24 Judicial facilities.** *Create a new subsection to read:* “Judicial facilities shall comply with Section 232 of ADAAG.”

## CSSB

Cedar Shake and Shingle Bureau  
P0 Box ff78  
Sumas, WA 98295-1178

Standard reference number	Title	Referenced in code section number
CSSB-97	Grading Rules.....	Table 1507.8.4, Table 1507.9.5

## DASMA

Door and Access Systems Manufacturer's  
Association International  
1300 Summer Avenue  
Cleveland, OH 44115-2851

Standard reference number	Title	Referenced in code section number
107-97	Room Fire Test Standard for Garage Doors Using Foam Plastic Insulation .....	2603.4.1.9

## DOC

Department of Commerce  
National Institute of Standards and Technology  
100 Bureau Drive Stop 3460  
Gaithersburg, MD 20899

Standard reference number	Title	Referenced in code section number
PS-1-95	Construction and Industrial Plywood .....	22 11.3. 1, 2303.1 4, 2304.6.2, Table 2304.7(4), 2306.3.2
PS-2-92	Performance Standard for Wood-based Structural-use Panels .....	1808.1.1, 2211.3. 1, 2303.1.4, 2304.6.2,
PS 20-99	American Softwood Lumber Standard .....	Table 2304.7(4), Table 2304.7(5), Table 2306. 3.1, 2306.3.2 1808 1.1, 2302, 2303.1.1

## DOJ

U.S. Department of Justice  
c/o Superintendent of Documents  
U.S. Government Printing Office  
Washington, DC 20402-9325

Standard Reference Number	Title	Referenced in code section number
36 CFR., Part <a href="#">1190-1191</a> <a href="#">Tuesday, November 16, 1999</a> <a href="#">Proposed Rule</a>	<a href="#">Americans with Disabilities Act (ADA) Accessibility Guidelines for Buildings and Facilities: Architectural Barriers Act (ABA) Accessibility Guidelines:</a>  <a href="#">ADAAG (Americans with Disability Act Accessibility Guidelines)</a> .....	406.2.2, 907.9.1.3, 1003.2.13.5.5, 1003.3.4, 1003.3.4.5.5, 1003.3.4.8, 1101.2, 1102.1, 1104.2.1, 1104.3.1, 1105.1, 1105.2, 1105.3, 1105., 1106.2, Table 1106.2, 1106.3, 1106.4, 1106.4.8, 1106.5, 1106.6, 1107.2, 1107.3, 1107.5.4, 1108.1, 1108.2 , 1108.2.1.1 1108.2.2, 1108.3, 1108.4, 1108.8, 1109.2.1, 1109.2.2.1, 1109.2.2.2, 1109.2.2.3, 1109.2.3, 1109.2.5, 1109.2.8, 1110.2, 1110.4, 1405.10.4, 1607.7, 3001.3, 3408.5, 3408.7.1, 3408.7.2

## DOL

U.S. Department of Labor  
c/o Superintendent of Documents  
U.S. Government Printing Office  
Washington, DC 20402-9325

Standard reference number	Title	Referenced in code section number
29 CFR 1910.1000-74	Air Contaminants.....	.902.1

KFPC-1999	KY Fire Prevention Code for Existing Buildings.....815 KAR 10:060, 2702.3, 3401.3, 3409.3.2
KPC-2000	Kentucky State Plumbing Code ..... 01.4.4, 102.6, 103.3, 201.3, 415.7.4, 716.5, 903.3.5, (815 KAR, Chapter 20), 1205.3.3, 1503.4, 1611.1, 1806.4.3, 2901.1, 3305.1, 3401.3, 3409.3.2
KY-2002	Kentucky Residential Code (ICC with Ky changes).....101.2, 2113.15, 3401.3
SBCCI SSTD 7-99	Standard for Soil Expansion Index Test .....1802.3 .2
SBCCI SSTD 10-99	Standard for Hurricane Resistant Residential Construction .....1609.1.1,2308.2.1
SBCCI SSTD 11-97	Standard for Determining Wind Resistance of Concrete or Clay Roof Tiles .....1715.2.1, 1715.2.2
SBCCI SSTD 12-97	Standard for Determining Impact Resistance from Windborne Debris .....1609.1.1
UBC Standard 18-2	Expansion Index Test.....1802.3.2
UBC 26-4-97	Method of Test for the Evaluation of Flammability Characteristics of Exterior, Nonload- Bearing Wall Panel Assemblies Using Foam Plastic Insulation .....2603 .5 .5
UWIC-2000	Urban Wildland Interface Cod .....Table 1505.1

## NCMA

National Concrete Masonry Association  
2302 Horse Pen Road  
Herndon, VA 22071-3499

Standard Reference Number	Title	Referenced in code section number
NCMA-TEK 5-8A-96	Design Details for Concrete Masonry Fire Walls .....	Table 719.I(2)

## NEMA

National Electrical Manufacturers Association  
2101 L Street, N.W., Suite 300  
Washington, DC 20037

Standard Reference Number	Title	Referenced in code section number
NEMA-250-97	Enclosures for Electrical Equipment (1000 volts. Max).....	1621.3.13.1
NEMA ICS 6-93	Industrial Control and System Enclosures.....	1621.3.13.1

## NFPA

National Fire Protection Association  
1 Batterymarch Park  
Quincy MA 02269-9101

Standard Reference Number	Title	Referenced in code section number
NFPA 11-02	Low Expansion Foam .....	904.7
NFPA 11A-99	Medium- and High-expansion Foam Systems .....	904.7
NFPA 12-00	Carbon Dioxide Extinguishing Systems .....	904.8, 904.11
NFPA 12A-97	Halon 1301 Fire Extinguishing Systems .....	904.9
NFPA 13-02	Installation of Sprinkler Systems .....	507.2, 704.12, 707.2, 903.3.1.1, 903.3.2, 903.3.5.1.1, 904.11, 907.8, 1621.3.10.1, 3104.5, 3104.9